

Certificate of Compliance

Certificate: 2011996 Master Contract: 236247

Project: 2011996 **Date Issued:** 2008/06/10

Issued to: ProvibTech, Inc.

11011 Brooklet Drive, Suite 360

Houston, TX 77099

USA

Attention: Mr. Donald Li

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Edward Foo, C.E.T.

Authorized by: Patricia Pasemko, Operations

talinga Pasem P)

Manager

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -

Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 2, Groups A, B, C & D:

PT2060-*** Monitor System, rated 220 Vac, 50/60 Hz, 4A, 110 Vac, 50/60 Hz, 6A, 110 Vdc, 6A or 24 Vdc,

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

DQD 507 Rev. 2004-06-30



Certificate: 2011996 Master Contract: 236247

Project: 2011996 **Date Issued:** 2008/06/10

16A max. Relay contact rated 240Vac, 5A or 24Vdc, 5A. Installed per Installation Manual PT2060-CAT-ENG-C-8704. Temperature Code T4, Tamb = - 40°C to +75°C.

Note: The model suffixes "***" denote 10/20/30/40/43/53/90/91/96 representing modules and power supplies.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2001) - General Requirements - Canadian Electrical Code, Part II

CSA C22.2 No. 0.4-04 - Bonding of Electrical Equipment

CSA Std. C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL Std No. 916, 3rd Ed. - 1998 - Energy Management Equipment

UL Std No. 1604, 3rd Ed. - 1994 - Electrical Equipment for Use in Class I and II, Division 2; Class III Hazardous (Classified) Locations



Supplement to Certificate of Compliance

Certificate: 2011996 Master Contract: 236247

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2011996	2008/06/10	CSAc/us Certification of Monitor System to Class I, Div. 2, Groups A, B, C & D Hazardous Location

History

Supplement Notes